



**CONSULTING ENGINEERS, D.P.C.**

MICHAEL J. LAMOREAUX, P.E. (NY, NJ, PA, VT, VA & CT)  
MICHAEL W. WEEKS, P.E. (NY, NJ & PA)  
LYLE R. SHUTE, P.E., LEED-AP (NY, NJ, PA)  
PATRICK J. HINES

Main Office  
33 Airport Center Drive  
Suite 202  
New Windsor, New York 12553

(845) 567-3100  
fax: (845) 567-3232  
e-mail: [mheny@mhepc.com](mailto:mheny@mhepc.com)

Principal Emeritus:  
RICHARD D. McGOEY, P.E. (NY & PA)

**TOWN OF NEWBURGH  
PLANNING BOARD  
TECHNICAL REVIEW COMMENTS**

**PROJECT: UNIFIRST CORPORTATION**  
**PROJECT NO.: 21-14**  
**PROJECT LOCATION: SECTION 34, BLOCK 2, LOT 38.32**  
**REVIEW DATE: 8 JULY 2021**  
**MEETING DATE: 15 JULY 2021**  
**PROJECT REPRESENTATIVE: PITINGARO & DOETSCH CONSULTING ENGINEERS, PC – JASON PITINGARO, P.E.**

1. The design report for the subsurface sanitary sewer disposal system and underground storm water system should be provided.
2. A revised Storm water Pollution Prevention Plan must be submitted addressing the additional paving now proposed.
3. Proposed new driveway is very close to the adjoining property. It is not clear it can be constructed without impacting the adjoining property .The property lines should be draw to be clearer on the plans.

Respectfully submitted,

**McGoey, Hauser and Edsall  
Consulting Engineers, D.P.C.**

Patrick J. Hines  
Principal

PJH/dns